

SUPPLIER DECLARATION of CONFORMITY

In accordance with AS4072.1-2005 B1

The product specified in this Declaration conforms to the following NZAS Standard:

Identification Number: 3M3000WT **NZAS Standard:** AS 1530.4-2014

Issuer Details:

N Z Manufacturer or Importer: Principal Products Ltd t/a Firestop Centre
Address: Unit J, 657 Great South Rd, Penrose, Auckland 1061
Telephone: (09) 483 4000
Email Address: info@firestopcentre.co.nz

Product Details:

Product Name: 3M™ Fire Barrier 3000WT Water Tight Sealant
Product Description: Used for sealing penetrations in fire-rated walls.

Approved Uses:

Substrate	Penetrant
Concrete Plasterboard Masonry (Hollow or Solid)	PEX pipes

Certification Bodies:


Name of Certifying Body	Address
Exova Warringtonfire Aus Pty Ltd	409 Hammond Rd, Dandenong, VIC 3175, Australia

Tests and Approvals:

Test Standard	Certificate or Reference No	Issue Date
AS 1530.4-2014 and AS 4072.1-2005	Regulatory Information Report RIR 45239800.1 and RIR 48815900.1	24/03/2017 08/01/2018

Reference to any management quality system involved:

Declaration:

Name and Designation as authorised by Issuer	Signature	Date
Gregory M Hand (Director)		25/8/18