

## Building Product Information Sheet | Class 1 FIRESTOP

Version V1 | 07/05/2026

<b>Product Name</b>	FIRESTOP Ultra Sealant
<b>Product Description</b>	FIRESTOP Ultra Sealant is a fire-rated, water-based acrylic intumescent sealant designed to maintain the fire resistance performance of fire-rated walls and floors where linear joints and service penetrations occur. Suitable for interior and exterior applications, the sealant provides flexibility and accommodates up to 20% joint movement. When exposed to fire, the sealant expands to form a durable insulating char that restricts the passage of fire and smoke through service openings and construction joints.
<b>Place of Manufacture</b>	Overseas - manufactured exclusively for Firestop Centre Ltd under controlled contract manufacturing and proprietary product specifications.
<b>Legal and Trading Name of Manufacturer</b>	Firestop Centre Limited
<b>NZBN</b>	9429031656054
<b>Address</b>	Unit J, 657 Great South Road Penrose Auckland 1061
<b>Contact Details</b>	✉ info@firestopcentre.co.nz ☎ 09 483 4000 🌐 firestopcentre.co.nz
<b>Relevant building Code Clauses</b>	C3 Fire affecting areas beyond the source
<b>Statement on how the Building Product is Expected to Contribute to Compliance:</b>	FIRESTOP Ultra Sealant has been tested and assessed to AS 1530.4:2014 and AS 4072.1:2005, providing fire resistance ratings (FRR) when applied to fire-rated substrates in accordance with the relevant tested system. Refer to <a href="http://firestopcentre.co.nz">firestopcentre.co.nz</a> for FC tech drawings, product information, and test reports.

<b>Limitations on the use of the Building Product:</b>	<p>To comply with relevant assessed systems to AS 1530.4:2014 and AS 4072.1:2005, the product must be installed as per the applicable FC tech drawing and documentation available at <a href="http://firestopcentre.co.nz">firestopcentre.co.nz</a>.</p> <p>Interior and exterior applications.</p>
<b>Design Requirements That Would Support the Appropriate Use of the Building Product:</b>	<p>FIRESTOP Ultra Sealant should be used for applications in fire-rated walls and floors where protection against the spread of fire, smoke, and sound through joints and service penetrations is required.</p> <p>The product must be installed in accordance with the relevant tested and assessed systems to AS 1530.4:2014 and AS 4072.1:2005. Suitable substrates include concrete, masonry, gypsum and steel construction materials.</p> <p>FIRESTOP Ultra Sealant is suitable for linear joints, gaps around service penetrations, and applications used in conjunction with Protecta FR Board and FIRESTOP Duct Wrap systems.</p>
<b>Installation Requirements</b>	<p>Refer to <a href="http://firestopcentre.co.nz">firestopcentre.co.nz</a> for FC tech drawings, product information, and test reports relating to specific application, design, and installation instructions. Products must not be modified in any way that may compromise performance. All fire-rated service penetrations must be labelled in accordance with AS 4072.1:2005.</p> <p>FIRESTOP products should be stored in a clean, dry location and kept in their original packaging prior to installation.</p>
<b>Maintenance Requirements</b>	<p>FIRESTOP passive fire protection products have no specific maintenance requirements. Damaged products should be repaired or replaced to maintain the required FRR of the fire-rated system.</p>
<b>Is the building Product/Building Product Line Subject to warning or Ban Under Section 26 of the Building Act 2004?</b>	<p>No</p>