

## Building Product Information Sheet | Class 1



Version V1 | 05/05/2026

<b>Product Name</b>	Mulcol Multicollar Slim and Multimastic SP
<b>Product Description</b>	<p>The Mulcol Multicollar Slim is a compact 30mm fire collar designed for sealing service penetrations in fire-rated walls and floors. Featuring a stainless-steel collar with a graphite inlay, it expands in fire to close openings created by melting pipes. Assessed to AS 1530.4:2014 and AS 4072.1:2005, it provides a reliable firestopping solution for a wide range of plastic, metal and composite penetrations. Multiclips and Multiscrews are included for fast installation.</p> <p>Mulcol Multimastic SP is an acrylic-based firestop sealant used with the Multicollar Slim to create a fire- and smoke-resistant seal around plastic pipe penetrations. It expands when exposed to heat, forming part of the complete Mulcol firestopping system.</p>
<b>Place of Manufacture</b>	The Netherlands
<b>Legal and Trading Name of Manufacturer</b>	Mulcol International
<b>Address</b>	Promenade 75 5401 GM Uden The Netherlands
<b>Legal and Trading Name of Importer</b>	Firestop Centre Limited
<b>NZBN</b>	9429031656054
<b>Address</b>	Unit J, 657 Great South Road Penrose Auckland 1061
<b>Contact Details</b>	<p>✉ info@firestopcentre.co.nz</p> <p>☎ 09 483 4000</p> <p>🌐 firestopcentre.co.nz</p>
<b>Relevant building Code Clauses</b>	C3 Fire affecting areas beyond the source
<b>Statement on how the Building</b>	Mulcol Multicollar slim has been assessed to AS 1530.4:2014 and AS 4072.1:2005, providing fire

<b>Product is Expected to Contribute to Compliance:</b>	<p>resistance ratings (FRR) when applied to fire-rated substrates in accordance with the relevant tested system.</p> <p>Refer to <a href="http://firestopcentre.co.nz">firestopcentre.co.nz</a> for FC tech drawings, product information, and test reports.</p>
<b>Limitations on the use of the Building Product:</b>	<p>To comply with assessed systems under AS 1530.4:2014 and AS 4072.1:2005, the product must be installed in accordance with the applicable FC technical drawings and documentation available at <a href="http://firestopcentre.co.nz">firestopcentre.co.nz</a>.</p> <p>Interior applications only.</p>
<b>Design Requirements That Would Support the Appropriate Use of the Building Product:</b>	<p>Mulcol Multicollar Slim should be used for interior applications in fire-rated walls and floors where protection against the spread of fire through service penetrations is required.</p> <p>The product must be installed in accordance with the relevant assessed systems to AS 1530.4:2014 and AS 4072.1:2005. Suitable substrates include concrete, masonry, and gypsum construction materials.</p> <p>Mulcol Multicollar Slim are suitable for service penetrations up to Ø315mm and must be used in conjunction with Mulcol Multimastic SP.</p>
<b>Installation Requirements</b>	<p>Refer to <a href="http://firestopcentre.co.nz">firestopcentre.co.nz</a> for FC tech drawings, product information, and test reports relating to specific application, design, and installation instructions.</p> <p>Products must not be modified in any way that may compromise performance. All fire-rated service penetrations must be labelled in accordance with AS 4072.1:2005.</p> <p>Mulcol products should be stored in a clean, dry location and kept in their original packaging prior to installation.</p>
<b>Maintenance Requirements</b>	<p>Mulcol passive fire protection products have no specific maintenance requirements. Damaged products should be repaired or replaced to maintain the required FRR of the fire-rated system.</p>
<b>Is the building Product/Building Product Line Subject to warning or Ban Under Section 26 of the Building Act 2004?</b>	<p>No</p>