

## Building Product Information Sheet | Class 1

Version V1 | 04/05/2026



<b>Product Name</b>	Protecta FR Acrylic
<b>Product Description</b>	Protecta FR Acrylic Sealant is a fire-rated acrylic sealant designed to prevent the spread of fire, smoke, and sound through joints and service penetrations in fire-rated walls and floors. Suitable for use with a wide range of construction materials, it provides up to 4 hours of fire resistance while maintaining acoustic performance. The sealant is commonly used around cables, pipes, and linear joints in commercial and residential building applications.
<b>Place of Manufacture</b>	United Kingdom
<b>Legal and Trading Name of Manufacturer</b>	Polyseam Limited
<b>Address</b>	15 St Andrew's Road Huddersfield West Yorkshire HD1 6SB
<b>Legal and Trading Name of Importer</b>	Firestop Centre Limited
<b>NZBN</b>	9429031656054
<b>Address</b>	Unit J, 657 Great South Road Penrose Auckland 1061
<b>Contact Details</b>	✉ info@firestopcentre.co.nz ☎ 09 483 4000 🌐 firestopcentre.co.nz
<b>Relevant building Code Clauses</b>	C3 Fire affecting areas beyond the source
<b>Statement on how the Building Product is Expected to Contribute to Compliance:</b>	Protecta FR Acrylic Sealant has been tested and assessed to AS 1530.4:2014 and AS 4072.1:2005, providing fire resistance ratings (FRR) when applied to fire-rated substrates in accordance with the relevant tested system.

	Refer to <b>firestopcentre.co.nz</b> for FC tech drawings, product information, and test reports.
<b>Limitations on the use of the Building Product:</b>	To comply with relevant tested and assessed systems to AS 1530.4:2014 and AS 4072.1:2005, the product must be installed as per the applicable FC tech drawing and documentation available at <b>firestopcentre.co.nz</b> .  Interior applications only.
<b>Design Requirements That Would Support the Appropriate Use of the Building Product:</b>	Protecta FR Acrylic Sealant should be used for interior applications in fire-rated walls and floors where protection against the spread of fire, smoke, and sound through joints and service penetrations is required.  The product must be installed in accordance with the relevant tested and assessed systems to AS 1530.4:2014 and AS 4072.1:2005. Suitable substrates include concrete, masonry, timber, gypsum, steel, and other non-porous construction materials.  Protecta FR Acrylic is suitable for linear joints, gaps around service penetrations, and applications used in conjunction with Protecta FR Board systems.
<b>Installation Requirements</b>	Refer to <b>firestopcentre.co.nz</b> for FC tech drawings, product information, and test reports relating to specific application, design, and installation instructions. Products must not be modified in any way that may compromise performance. All fire-rated service penetrations must be labelled in accordance with AS 4072.1:2005.  Protecta products should be stored in a clean, dry location and kept in their original packaging prior to installation.
<b>Maintenance Requirements</b>	Protecta passive fire protection products have no specific maintenance requirements. Damaged products should be repaired or replaced to maintain the required FRR of the fire-rated system.
<b>Is the building Product/Building Product Line Subject to warning or Ban Under Section 26 of the Building Act 2004?</b>	No