

Building Product Information Sheet | Class 1 FIRESTOP

Version V1 | 07/05/2026

Product Name	FIRESTOP Duct Hatch
Product Description	FIRESTOP Duct Access Hatches are fire-rated access hatches designed for use with FIRESTOP Duct Wrap-38 systems to maintain the fire resistance performance of fire-rated duct penetrations. Suitable for both rectangular and circular ducts, the hatches provide a tested firestopping solution while allowing access for inspection, maintenance, and servicing of ductwork systems.
Place of Manufacture	New Zealand - manufactured exclusively for Firestop Centre Ltd under controlled contract manufacturing and proprietary product specifications.
Legal and Trading Name of Manufacturer	Firestop Centre Limited
NZBN	9429031656054
Address	Unit J, 657 Great South Road Penrose Auckland 1061
Contact Details	✉ info@firestopcentre.co.nz ☎ 09 483 4000 🌐 firestopcentre.co.nz
Relevant building Code Clauses	C3 Fire affecting areas beyond the source
Statement on how the Building Product is Expected to Contribute to Compliance:	FIRESTOP Duct Hatches have been tested and assessed to AS 1530.4:2014(Section 9 and 10) and AS 4072.1:2005, providing fire resistance ratings (FRR) for metal ducts protected with FIRESTOP Duct Wrap-38 where access to the inside of the duct is required. Refer to firestopcentre.co.nz for FC tech drawings, product information, and test reports.
Limitations on the use of the Building Product:	To comply with relevant assessed systems to AS 1530.4:2014(Section 9 and 10) and AS 4072.1:2005, the product must be installed as per the applicable FC tech drawing and documentation available at firestopcentre.co.nz . For use in the interior of buildings.

<p>Design Requirements That Would Support the Appropriate Use of the Building Product:</p>	<p>FIRESTOP Duct hatch is suitable for applications on rectangular metal ductwork min. duct width of 310mm and circular metal ductwork with a min. diameter of 300mm, protected with FIRESTOP Duct Wrap-38. The system has been tested for both internal and external fire exposure conditions, including kitchen exhaust systems.</p> <p>The product must be installed in accordance with the relevant tested and assessed systems to AS 1530.4:2014 and AS 4072.1:2005.</p> <p>Ductwork to be constructed in accordance with AS 4245.2-2012 Pressure class 500 or higher.</p>
<p>Installation Requirements</p>	<p>Refer to firestopcentre.co.nz for FC tech drawings, product information, and test reports relating to specific application, design, and installation instructions.</p> <p>Products must not be modified in any way that may compromise performance. All fire-rated service penetrations must be labelled in accordance with AS 4072.1:2005.</p> <p>FIRESTOP products should be stored in a clean, dry location and kept in their original packaging prior to installation.</p>
<p>Maintenance Requirements</p>	<p>FIRESTOP passive fire protection products have no specific maintenance requirements. Damaged products should be repaired or replaced to maintain the required FRR of the fire-rated system.</p>
<p>Is the building Product/Building Product Line Subject to warning or Ban Under Section 26 of the Building Act 2004?</p>	<p>No</p>