



FIRESTOP CENTRE

Authorised New Zealand Distributor

Ph (09) 483 4000 www.firestopcentre.co.nz

FIRESTOP Duct Hatch - Guide to Minimum Duct Dimensions

Rectangular Ducts

<u>FIRESTOP Duct Hatch</u>	<u>Duct Hole Size</u>	<u>Lid & Frame Size</u>	<u>Min Duct Width</u>
Small (Equivalent to AP3)	120 x 200mm	310 x 390mm	310mm
Medium (Equivalent to AP2)	200 x 330mm	390 x 520mm	390mm
Large (Equivalent to AP1)	330 x 450mm	520 x 640mm	520mm

Circular Ducts

Hatches for circular ducts are made to fit the required duct diameter. The lid size will be one of the above rectangular sizes.

Small requires minimum duct diameter of 300mm.

Medium requires minimum duct diameter of 400mm.

Large requires minimum duct diameter of 500mm.