



FIRESTOP CENTRE
INNOVATIVE FIRESTOP SOLUTIONS

SUPPLIER CERTIFICATE of COMPLIANCE

In accordance with AS4072.1-2005 B1

The product specified in this Certificate meets industry insulation standards

Identification Number:	ALUTHERM	NZ Standard:	NZBC H1
-------------------------------	-----------------	---------------------	----------------

Issuer Details:

N Z Manufacturer or Importer:	Firestop Centre Ltd (NZ Co # 2408906)
Address:	Unit J, 657 Great South Rd, Penrose, Auckland 1061
Telephone:	(09) 483 4000
Email Address:	info@firestopcentre.co.nz

Product Details:

Product Name:	Firestop Centre Alutherm Thermal Wrap
Product Description:	Used for wrapping HVAC ducts to provide thermal insulation

Approved Uses:

Substrate	Penetrant
Concrete Walls and Floors Plasterboard Walls	HVAC ducts

Tests and Approvals:

Test Standard	Certification Results
GB/T 13350-2008 GB/J47-83	Thermal Resistance R-value 0.7m ² K/W Density 24/kg/m ³ Thermal Conductivity <= 0.036w/mK Service Temperature -120°C to +450°C Non-Combustible (Grade A) Sound Absorption Coefficient 0.90 (reverberation Positioning 2000HZ) Water Content < 1%

Declaration:

Name and Designation as authorised by Issuer	Signature	Date
Gregory M Hand (Director)		25/11/20