



SUPPLIER CERTIFICATE of COMPLIANCE

In accordance with AS4072.1-2005 B1

FIRESTOP CENTRE
INNOVATIVE FIRESTOP SOLUTIONS

The product specified in this Certificate conforms to the following NZAS Standard:

Identification Number:	TRAWRAP1.5	NZAS Standard:	AS 1530.4-2014
-------------------------------	-------------------	-----------------------	-----------------------

Issuer Details:

N Z Manufacturer or Importer:	Firestop Centre Ltd (NZ Co # 2408906)
Address:	Unit J, 657 Great South Rd, Penrose, Auckland 1061
Telephone:	(09) 483 4000
Email Address:	info@firestopcentre.co.nz

Product Details:

Product Name:	Trafalgar FyreWrap™ Duct Wrap
Product Description:	Used for wrapping grease ducts or air ducts for protection from internal or external fire.

Approved Uses:

Substrate	Penetrant
Concrete Walls and Floors Plasterboard Walls	Grease ducts or air ducts

Certification Bodies:

Name of Certifying Body	Address
BRANZ CSIRO	1222 Moonshine Rd, Porirua 5381, NZ 14 Julius Ave, Nth Ryde, NSW 2113, Australia

Tests and Approvals:

Test Standard	Certificate or Reference No	Issue Date
AS 1530.4-2014	BRANZ Fire Technical Opinion FAR 4205 CSIRO Assessment Report FCO-3226	16/07/2014 10/07/2020

Reference to any management quality system involved:

Declaration:

Name and Designation as authorised by Issuer	Signature	Date
Gregory M Hand (Director)		25/11/20