

# Emission Test Certificate

Wednesday, November 07, 2012

Supplier: Unifrax Australia Pty Ltd (336 Settlement Rd, Thomastown, VIC, 3074)

Sample Description: FyreWrap

Date Tested: October 2012


Test Method: ASTM D5116 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products".

Emission Data:

<b>Specification</b>  <b>Green Building Council of Australia</b> <b>Green Star Office Design V2/V3 IEQ-13</b>	<b>FyreWrap</b>
Total Volatile Organic Compound emission rate $<0.5 \text{ mg/m}^2/\text{hr}$	Total Volatile Organic Compound emission rate $0.422 \text{ mg/m}^2/\text{hr}$



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Travis Hale  
BSc  
Consultant

**CV121009**