



Step-by-step installation instructions:

1. Ensure the aperture is free from dust and debris.
2. Cut 150mm wide AGNI-Sleeve (100mm for the protection within the concrete floor/ceiling and 50mm for fixing tabs) to fit one revolution of the AGNI-Sleeve into the aperture.
3. Cut the AGNI-Sleeve to make two 50mm high x 25mm wide fixing tabs.
4. Insert the AGNI-Sleeve into the aperture from above flush with the concrete floor/ceiling surface.
5. Leave the tabs protruding above the top of the concrete floor/ceiling surface.
6. Bend the fixing tabs over onto the surface of the floor/ceiling and secure them using concrete anchors.
7. Apply a bead of AGNI-Seal (10mm nominal) between the floor/ceiling, AGNI-Sleeve and the pipe, finishing flush with the face of the floor/ceiling.



Technical Information

Substrate	Min. 100mm concrete ceiling/floor
Service range	DN32mm up to DN90mm PP-R pipes
Annular gap	4.5 - 8.3mm
AGNI-Products	AGNI-Sleeve, AGNI-Seal
Protection installation	Asymmetrical (installed from above the floor/ceiling)

Compliance Information

Standards	AS1530.4-2014, AS4072.1-2005
FRR/FRL	-/120/120
Reference	PF24122

Disclaimer

Agnitek reserves the right to modify product specifications without prior notice due to its ongoing research, development & certification programme. The information in this document is provided in good faith and is intended for guidance purposes only. Any accompanying drawings are solely for illustrative purposes. Since Agnitek cannot oversee installation methods or ensure site conditions, no warranties, expressed or implied, are intended regarding the products' actual performance. We do not accept liability for any loss, damage, or injury from using this information. Please take a look at the test reports displayed on a relevant AGNI-System webpage for all compliance specifics.




FIRESTOP CENTRE

Authorised New Zealand Distributor
Ph (09) 483 4000 www.firestopcentre.co.nz

AGNI-Sleeve in 100mm Concrete Floor/Ceiling 32-90mm PPR Pipe, Top Fix FRR -/120/120

Page 2 of 2



Technical Information

Substrate	Min. 100mm concrete ceiling/floor
Service range	DN32mm up to DN90mm PP-R pipes
Annular gap	4.5 - 8.3mm
AGNI-Products	AGNI-Sleeve, AGNI-Seal
Protection installation	Asymmetrical (installed from above the floor/ceiling)

Compliance Information

Standards	AS1530.4-2014, AS4072.1-2005
FRR/FRL	-/120/120
Reference	PF24122



8 Clare St Bayswater
VIC 3153, AUSTRALIA
www.agnitek.com.au

Disclaimer

Agnitek reserves the right to modify product specifications without prior notice due to its ongoing research, development & certification programme. The information in this document is provided in good faith and is intended for guidance purposes only. Any accompanying drawings are solely for illustrative purposes. Since Agnitek cannot oversee installation methods or ensure site conditions, no warranties, expressed or implied, are intended regarding the products' actual performance. We do not accept liability for any loss, damage, or injury from using this information. Please take a look at the test reports displayed on a relevant AGNI-System webpage for all compliance specifics.

Date	20.06.2024
------	------------