

## Allproof Low Profile Fire Collar PVC Plastic Floor Waste in Concrete Floor (from 70mm) with Rib & Timber Infill

System/FPA Register ID# FC734


<b>Products</b>	Allproof Low-Profile Fire Collar
<b>Application</b>	Fire stopping of floor wastes in rigid floors
<b>Construction</b>	Minimum floor thickness of 70mm and comprise aerated concrete or concrete

**Fire Classification:**

In 70mm floor slab with 25mm timber infill: 80mm diam with annular space up to 6mm FRR -/120/120
100mm diam with annular space up to 8.5mm FRR -/120/120

**INSTALLATION INSTRUCTIONS:**

1. Ensure substrate around pipe is flat and free from obstructions.
2. Open pipe collar and position around pipe.
3. Slide tab through slot in pipe collar and fold back 180° to secure.
4. Secure pipe collar using M6x60 masonry anchors passing through the timber into the concrete slab. Do not use fixings which rely on plastic or nylon components for grip.
5. Install only from underside on floor penetrations.



As a part of our policy of on-going product development and testing, we reserve the right to modify, alter or change product specifications without giving notice. All information contained in this document is given in good faith and is provided for guidance only. Any drawings provided are for illustrative purposes only. As Firestop Centre has no control over the methods or competence of installation and of prevailing site conditions, no warranties, expressed or implied, is intended to be given as to the actual performance of the product mentioned or referred to herein and no liability whatsoever will be accepted for any loss, damage or injury arising from the use of the information given.

For all technical details on the products specified please refer to the technical data sheets that can be found on [www.firestopcentre.co.nz](http://www.firestopcentre.co.nz)

Signed and approved:

# ALLPROOF

INDUSTRIES

Allproof Industries Ltd  
 17 Bay Park Place  
 Beach Haven, AK 0626

Sheet size: <b>A4</b>	Drawn date & no: 28/7/21
Scale: <b>NTS</b>	Drawn by: G.P