

FIRESTOP Gap Seal
 Concrete Floor 120mm or greater
 Gap 50mm

System/FPA Register ID# FC790

| | |
|---------------------|---|
| Products | FIRESTOP Gap Seal |
| Application | Fire stopping of 50mm linear gap in concrete floor slab |
| Construction | Concrete floor slab min 120mm thick |

Fire Classification

FIRESTOP Gap Seal (3 section) friction fitted flush with bottom of concrete slab

FRR -/60/60

INSTALLATION INSTRUCTIONS

1. Ensure surfaces are free of grease or other contaminants.
2. Compress the FIRESTOP Gap Seal strip into the linear gap and position. approx flush with bottom side of slab.
3. Add strips by placing in position and ensured a tight butt fit to adjoining strip.



As a part of our policy of on-going product development and testing, we reserve the right to modify, alter or change product specifications without giving notice. All information contained in this document is given in good faith and is provided for guidance only. Any drawings provided are for illustrative purposes only. As Firestop Centre has no control over the methods or competence of installation and of prevailing site conditions, no warranties, expressed or implied are intended to be given as to the actual performance of the product mentioned or referred to herein and no liability whatsoever will be accepted for any loss, damage or injury arising from the use of the information given.

For all technical details on the products specified please refer to the technical data sheets that can be found on www.firestopcentre.co.nz

Signed and approved:



Firestop Centre Ltd
 657 Great South Road
 Epsom, AUCKLAND

| | |
|--------------------------|-----------------------------|
| Sheet size: A4 | Drawn date & no: 20/8/23 |
|--------------------------|-----------------------------|