



Protecta FR Acrylic
Blank Seal up to 300x300mm
in Concrete Wall from 75mm

Authorised New Zealand Distributor
Ph (09) 483 4000 www.firestopcentre.co.nz

Installation Instructions


- Before installing Protecta® FR Acrylic ensure that the surface of all service penetrations and surrounding construction is free from all loose contaminants, dust and grease.
- Where Protecta® FR Acrylic is to be installed against surfaces that cannot tolerate direct contact; appropriate surface preparation should be made (contact Polyseam for guidance in these cases). For paints sensitive to sealing compounds, priming with a PVA primer is recommended.
- When installing any backing material, cut this slightly oversize and insert into the gap ensuring a tight friction fit. Ensure correct depth is achieved.
- Fill the gap or joint with Protecta® FR Acrylic to the required depth.
- Apply the sealant generously to prevent air bubbles.
 Finish the bead with a moist spatula, pallet knife or brush.
- Protecta® FR Acrylic can be over-painted with most emulsion or alkyd (gloss) paints.





Protecta FR Acrylic 12.5 - 25mm Single-sided seal may be anywhere within the wall





Backing may be Protecta Mineral Fibre BIO or any stone wool or mineral wool 35kg/m³

ECTA warringtonfire

ETA 21-0046 FAS 190390 AS1530.4-2014 AS4072.1-2005

As a part of our policy of on-going product development and testing, we reserve the right to modify, alter or change product specifications without giving notice. All information contained in this document is given in good faith and is provided for guidance only. Any drawings provided are for illustrative purposes only. As Polyseam has no control over the methods or competence of installation and of prevailing site conditions, no warranties, expressed or implied, is intended to be given as to the actual performance of the product mentioned or referred to herein and no liability whatsoever will be accepted for any loss, damage or injury arising from the use of the information given.



warringtonfire

FAS 190390 Page 17, 19, 32, 37, 8 AS1530.4-2014 AS4072.1-2005

System/FPA Register ID# FC259

Products

Protecta FR Acrylic

Stone wool

Application

Fire rated blank seal in rigid wall

Construction

Minimum wall thickness of 75mm and comprise concrete, aerated concrete or masonry, with a density of ≥ 650 kg/m³

Fire & Sound classification

In 150mm wall:

Protecta Acrylic 25mm single-sided with 48mm backing up to 300mm x 300mm aperture

FRR -/240/60

Protecta Acrylic 25mm single-sided with 48mm backing up to 35mm x 35mm or 36mm diam

FRR-/240/120

Protecta Acrylic 15mm double-sided with 25mm backing up to 300mm x 300mm aperture

FRR -/240/240

In 100mm wall:

Protecta Acrylic 12.5mm double-sided with 20mm backing up to 300mm x 300mm aperture

FRR-/120/120

In 75mm wall:

Protecta Acrylic 12.5mm double-sided with no backing up to 150mm x 150mm aperture

FRR-/60/60

ZERO smoke leakage up to 200Pa

Sound reduction (seal only)

STC 62

Sheet size:	Drawn date & no:
A4	24/5/20
Scale:	Drawn by:
NTS	K.B