


Authorised New Zealand Distributor Ph (09) 483 4000 www.firestopcentre.co.nz

Protecta FR Board Solid Timber or CLT Wall 100mm Plastic Conduits (single or in bundles)

Installation Instructions

- 1. Before installing Protecta® FR Board ensure that the surface of all service penetrations and surrounding construction is free from all loose contaminants, dust and grease.
- 2. The FR Board may be 50mm or 60mm with coated side facing outwards.
- 3. Cut the required boards to suit the aperture dimensions and penetrant.
- 4. The FR Board must oversail the aperture by 100mm and be bonded to the wall with a bead of Protecta® FR Acrylic. Fix with 100mm wood screws and penny washers at corners and at 300mm centres 50mm in from edge.
- 5. All joints, gaps or imperfections in the installed seal must be filled with Protecta® FR Acrylic on both sides.
- Protecta® FR Board can be over-painted with most emulsion or alkyd (gloss) paints.

NOTE: Smaller conduits can be bundled up to 110mm diam and wrapped as a single unit. Fill annular space with FR Acrylic.





Minimum separations and limitations

Maximum aperture

1200mm wide by

600mm high

Cables

≤ Ø14mm

single or in

Plastic conduit

partially or fully

filled with cables

Protecta

FR Acrylic

a bundle

An aperture can include several services, and they may also be different. The minimum permitted separation between adjacent seals/apertures is 200mm. Services should be a minimum of 25mm from seal edges. Services within the system Protecta® FR Board seal do not require a minimum separation, except pipes where pipe insulation penetrates the seal and plastic pipe penetrations which should be a minimum of 30 mm from other services in the aperture. The total amount of cross sections of services (including insulation) should not exceed 60% of the penetration area.

ECTA warringtonfire

ETA 21-0047 FAS 200262 AS1530.4-2014 AS4072.1-2005

As a part of our policy of on-going product development and testing, we reserve the right to modify, alter or change product specifications without giving notice. All information contained in this document is given in good faith and is provided for guidance only. Any drawings provided are for illustrative purposes only. As Polyseam has no control over the methods or competence of installation and of prevailing site conditions, no warranties, expressed or implied, is intended to be given as to the actual performance of the product mentioned or referred to herein and no liability whatsoever will be accepted for any loss, damage or injury arising from the use of the information given.

For all technical details on the products specified please refer to the technical data sheets that can be found on www.protecta.eu

Signed and approved:

warringtonfire

FAS 200262 Page 72.9 AS1530.4-2014 AS4072.1-2005

System/FPA Register ID# FC592

Products Protecta FR Board

> Protecta FR Acrylic Protecta FR Pipe Wrap

Fire stopping of conduits in **Application**

timber walls

Construction Minimum wall thickness of

> 100mm and comprise solid timber or CLT with a minimum

density of 510kg/m3

Fire & Sound classification

For 100mm walls:-

1 layer 50mm 1-S or

60mm 2-S FR Board

each side

Protecta Pipe Wrap 2

lavers of 50mm wide

All services and openings must be sealed with FR

fitted both sides

Acrylic both sides

All conduits may be empty, partially filled or filled with cables up to 14mm diam - conduits may be PVC-U, PVC-C, PE, PE-HD, PEX, PP, PP-R, PP-H:

All single conduits ≤ Ø110mm diam

FRR -/120/90

Bundles ≤ Ø110mm of smaller conduits (may be a mixture of PVC to 32mm, others to 40mm)

FRR -/90/90

Smoke-safe (<0.1m³/h smoke leakage at 200Pa)

Sound reduction (seal only)

STC 52



Sheet size:	Drawn date & no:
A4	5/3/19
Scale:	Drawn by:
NTS	K.B