

# Regulatory Information Report

**RIR2206401**

## Fire Resistance Test for Linear Joints in FR Plasterboard Wall

Issued to:	Firestop Centre Ltd
Test method:	AS1530.4-2014
Report Date:	08/07/2025
Test number:	PF22064

# Table of Contents

1.1	Document revision schedule .....	3
1.2	Signatories .....	3
2.	Report Summary .....	4
3.	General Information .....	5
3.1	Testing Scope .....	5
3.2	Contact Details .....	5
3.3	Specimen Preparation, Conditioning and Timeline .....	6
3.4	Use of the Report .....	6
4.	Specimen Description .....	7
4.1	Supporting Construction .....	7
4.2	Specimen A .....	8
4.3	Specimen B .....	8
4.4	Specimen C .....	9
4.5	Specimen D .....	9
4.6	Specimen E .....	9
5.	Test Results .....	10
5.1	Observations during the test .....	10
5.2	Specimen A – 5mm Vertical Linear Gap .....	11
5.3	Specimen B – 10mm Vertical Linear Gap .....	12
5.4	Specimen C – 15mm Vertical Linear Gap .....	13
5.5	Specimen D – 20mm Vertical Linear Gap .....	14
5.6	Specimen E – 40mm Horizontal Linear Gap .....	15
6.	Photos .....	16

## 1.1 Document revision schedule

Revision #	Date	Description
1	08/07/2025	Issued

## 1.2 Signatories

Report	Name	Signature	Date
Prepared by:	Alexey Kokorin		08/07/2025
Authorised by:	Andrew Bain (Authorized signatory)		08/07/2025



All tests reported herein  
have been performed in  
accordance with the  
laboratory's scope of  
accreditation

## 2. Report Summary

A concrete lintel and two separate 64mm steel stud/track wall, lined with 1 x 16mm FR plasterboard on each side was constructed. To construct each steel stud wall, 2 x studs faced back to back were installed at 250mm centres, with 5mm, 10mm, 15mm and 20mm linear gaps within the steel frame. This was repeated for both steel stud frames. Insulation was installed in each cavity, and the spacing between the two steel stud frames was 20mm. Plasterboard was installed short of the lintel, resulting in a 40mm gap between the top of the plasterboard and lintel. Plasterboard was trimmed to reveal 5mm, 10mm, 15mm and 20mm linear gaps. PEF Rod was recessed 16mm from both sides, then filled with a bead of FIRESTOP Ultra sealant, flush with the surface of the plasterboard.

Specimen	Joint	Actual Integrity (min)	Actual Insulation (min)	FRL
<b>A</b>	5mm Vertical Linear Gap seal	93 NF	93 NF	-/90/90
<b>B</b>	10mm Vertical Linear Gap seal	93 NF	93 NF	-/90/90
<b>C</b>	15mm Vertical Linear Gap seal	93 NF	93 NF	-/90/90
<b>D</b>	20mm Vertical Linear Gap seal	93 NF	91	-/90/90
<b>E</b>	40mm Horizontal Linear Gap seal	93 NF	93 NF	-/90/90

NF indicates no failures observed during test

## 3. General Information

---

### 3.1 Testing Scope

**Applicable Standards:**

AS 1530-2014 Part 4: Section 10 Service penetrations and control joints.

AS 4072.1-2005 Part 1: Service penetrations and control joints

**Departures from Testing Method:**

No departures from the testing method

**Test conditions:**

Conditions complied with the Standard

### 3.2 Contact Details

**Accredited Testing Laboratory**

FTSL - Passive Fire Inspection and Test Services Ltd

Accreditation Number - 1335

1/113 Pavilion Drive, Mangere, Auckland, 2022

New Zealand

Contact e-mail: [tests@firelab.co.nz](mailto:tests@firelab.co.nz)

**Issued to:**

Firestop Centre Ltd.

657 Great South Rd, Penrose, Auckland, 1061

New Zealand

Contact e-mail: [info@firestopcentre.co.nz](mailto:info@firestopcentre.co.nz)

### 3.3 Specimen Preparation, Conditioning and Timeline

#### **Specimens conditioning and delivery to Laboratory:**

Separating element was built by the Laboratory in line with Client instructions. Installation of fire stopping system was performed by the Client. The Laboratory was not involved in sampling of the materials. The Laboratory checked materials during construction of the specimen.

#### **Testing date:**

11/11/2022

#### **Installation completion date:**

17/10/2022

#### **Termination of The Test:**

The test was discontinued at 93 minutes.

### 3.4 Use of the Report

A regulatory information report was issued in addition to the full test report PF22064. This provides the minimum information required for regulatory compliance

This report shall not be reproduced, except in full. The specimen was a symmetrical construction. The results of the test apply if exposed to fire from either side.

This report details the methods of construction, test conditions and the results obtained when the specific element of construction described herein was tested following the procedure outlined in AS 1530.4. Any significant variation with respect to size, constructional details, loads, stresses, edge or end conditions, other than that allowed under the field of direct application in the relevant test method, is not covered by this report.

Because of the nature of fire resistance testing and the consequent difficulty in quantifying the uncertainty of measurement of fire resistance, it is not possible to provide a stated degree of accuracy of the result.

The test results relate to the specimens of the product in the form in which they were tested. Differences in the composition or thickness of the product may significantly affect the performance during the test and may therefore invalidate the test results. Care should be taken to ensure that any product, which is supplied or used, is fully represented by the specimens, which were tested.

The specimens were supplied by the sponsor and the Laboratory was not involved in any of selection or sampling procedures. The results of these fire tests may be used

to directly assess fire hazard, but it should be recognized that a single test method will not provide a full assessment of fire hazard under all fire conditions.

## 4. Specimen Description

### 4.1 Supporting Construction

Separating Element		
1.1	Item / Product Name	Steel Stud and Plasterboard Separating Element
	Dimensions	Width / Height (W/H): 1200mm x 1200mm
		Thickness (T): 292mm
1.2	Item / Product Name	64mm Steel Stud
	Dimensions	Width / Height (W/H): 64mm x 35.5mm
		Thickness (T): 0.75 bmt
	Additional Info	Used to create steel stud frame
1.3	Item / Product Name	Wall Track
	Dimensions	Width / Height (W/H): 64mm x 28mm
		Thickness (T): 0.70 bmt
	Additional Info	Installed to bottom of steel frame
1.4	Item / Product Name	Deflection Head Track
	Dimensions	Width / Height (W/H): 64mm x 50mm
		Thickness (T): 0.70 bmt
	Additional Info	Installed to lintel
1.5	Item / Product Name	16mm FR Plasterboard
	Dimensions	Width / Height (W/H): 1200mm x 1200mm
		Thickness (T): 16mm
	Additional Info	Used to line steel stud frame
1.6	Item / Product Name	Concrete Slab Head
	Dimensions	Width / Height (W/H): 1200mm x 150mm
		Depth (T): 600mm
	Additional Info	Attached to top of refractory frame
1.7	Item / Product Name	Wall Insulation

	Dimensions	Width / Height (W/H): 1140mm x 560mm
		Thickness (T): 75mm
		Insulation Rating: R1.8
	Additional Info	Installed within steel stud frame
4.1	Item / Product Name	Self-drilling Screws
	Dimensions	25mm
	Installation	Used to fix steel stud frame together
4.2	Item / Product Name	Self-Tapping Screws
	Dimensions	32mm
	Installation	Used to fix the first layer of plasterboard to the steel studs and tracks

## 4.2 Specimen A

3.1	Item / Product Name	Formulation F023SDW01 - FIRESTOP Ultra sealant
	Dimensions	600mL
	Installation	Used to seal linear gaps within frame
5.1	Item / Product Name	10mm PEF Rod
	Dimensions	Length (L): 1000mm
		Outer Diameter (OD): 10mm
	Installation	Installed in linear gaps

## 4.3 Specimen B

3.1	Item / Product Name	Formulation F023SDW01 - FIRESTOP Ultra sealant
	Dimensions	600mL
	Installation	Used to seal linear gaps within frame
5.1	Item / Product Name	10mm PEF Rod
	Dimensions	Length (L): 1000mm
		Outer Diameter (OD): 10mm
	Installation	Installed in linear gaps



#### 4.4 Specimen C

3.1	Item / Product Name	Formulation F023SDW01 - FIRESTOP Ultra sealant
	Dimensions	600mL
	Installation	Used to seal linear gaps within frame
5.2	Item / Product Name	20mm PEF Rod
	Dimensions	Length (L): 1000mm
		Outer Diameter (OD): 20mm
	Installation	Installed in linear gaps

#### 4.5 Specimen D

3.1	Item / Product Name	Formulation F023SDW01 - FIRESTOP Ultra sealant
	Dimensions	600mL
	Installation	Used to seal linear gaps within frame
5.2	Item / Product Name	20mm PEF Rod
	Dimensions	Length (L): 1000mm
		Outer Diameter (OD): 20mm
	Installation	Installed in linear gaps

#### 4.6 Specimen E

3.1	Item / Product Name	Formulation F023SDW01 - FIRESTOP Ultra sealant
	Dimensions	600mL
	Installation	Used to seal linear gap within frame


## 5. Test Results

### 5.1 Observations during the test

Time Minutes	Test Face	SP	Observations
5	E	SE	Exposed face of plasterboard has combusted
5	E	A, B, C, D, E	Sealant glowing red, with cracks/lines in sealant
10	E	A, B, C, D, E	Further visible cracks through seal
10	E	A, B, C, D, E	Visible expansion of sealant
20	E	D, E	Sections of expanded sealant has fallen from specimen
30	E	A, B, C, D, E	Further expansion of sealant
44	U	E	Visible smoke from seal on junction with concrete slab, near TC39
45	E	A, B, C, D, E	Further expansion of sealant
45	E	A, B, C	Sections of expanded sealant has fallen from specimen
60	E	A, D	Majority of sealant has separated from the plasterboard
74	U	D, E	Visible expansion of seal
77	U	E	Visible bulges in sealant
80	U	B, C	Visible expansion of seal
90	E	B, C	Majority of sealant has separated from the plasterboard
93			TEST DISCONTINUED

**NOTE: E – Exposed Face (inside furnace),  
U – Unexposed Face (outside furnace)  
SE – Separating element**


## 5.2 Specimen A – 5mm Vertical Linear Gap



Service	5mm wide Vertical Linear Gap seal
Joint Details	Sealant (3.1), PEF Rod (5.1)
<b>Local Fire-stopping Protection</b>	
Application	Symmetrical
Protection Used	A PEF rod (5.1) was inserted into the linear gap aperture, recessed 16mm. A bead of sealant was applied on top of the PEF rod, flush with the surface of the plasterboard, resulting in a sealant depth of 16mm

<b>Structural adequacy</b>	<b>Not applicable</b>
<b>Integrity</b>	<b>No failure at 93 min</b>
<b>Insulation</b>	<b>No failure at 93 min</b>


### 5.3 Specimen B – 10mm Vertical Linear Gap



Service	10mm wide Vertical Linear Gap seal
Joint Details	Sealant (3.1), PEF Rod (5.1)
<b>Local Fire-stopping Protection</b>	
Application	Symmetrical
Protection Used	A PEF rod (5.1) was inserted into the linear gap aperture, recessed 16mm. A bead of sealant was applied on top of the PEF rod, flush with the surface of the plasterboard, resulting in a sealant depth of 16mm

<b>Structural adequacy</b>	<b>Not applicable</b>
<b>Integrity</b>	<b>No failure at 93 min</b>
<b>Insulation</b>	<b>No failure at 93 min</b>


## 5.4 Specimen C – 15mm Vertical Linear Gap



Service	15mm wide Vertical Linear Gap seal
Joint Details	Sealant (3.1), PEF Rod (5.2)
<b>Local Fire-stopping Protection</b>	
Application	Symmetrical
Protection Used	A PEF rod (5.1) was inserted into the linear gap aperture, recessed 16mm. A bead of sealant was applied on top of the PEF rod, flush with the surface of the plasterboard, resulting in a sealant depth of 16mm

<b>Structural adequacy</b>	<b>Not applicable</b>
<b>Integrity</b>	<b>No failure at 93 min</b>
<b>Insulation</b>	<b>No failure at 93 min</b>


## 5.5 Specimen D – 20mm Vertical Linear Gap



Service	20mm wide Vertical Linear Gap seal
Joint Details	Sealant (3.1), PEF Rod (5.2)
<b>Local Fire-stopping Protection</b>	
Application	Symmetrical
Protection Used	A PEF rod (5.1) was inserted into the linear gap aperture, recessed 16mm. A bead of sealant was applied on top of the PEF rod, flush with the surface of the plasterboard, resulting in a sealant depth of 16mm

<b>Structural adequacy</b>	<b>Not applicable</b>
<b>Integrity</b>	<b>No failure at 93 min</b>
<b>Insulation</b>	<b>91 min</b>

## 5.6 Specimen E – 40mm Horizontal Linear Gap



Service	40mm wide Horizontal Linear Gap seal
Joint Details	Sealant (3.1)
<b>Local Fire-stopping Protection</b>	
Application	Symmetrical
Protection Used	Sealant was applied between the top of the plasterboard and the concrete slab. The sealant was applied directly to the deflection head track, flush with the surface of the plasterboard, resulting in a sealant depth of 16mm


<b>Structural adequacy</b>	<b>Not applicable</b>
<b>Integrity</b>	<b>No failure at 93 min</b>
<b>Insulation</b>	<b>No failure at 93 min</b>



## 6. Photos

---

Unexposed faced:



Exposed face:

