

Regulatory Information Report

RIR2207601

Fire Resistance Test for Linear Joints and Penetrations in FR Plasterboard Wall

Issued to:	Firestop Centre Ltd
Test method:	AS1530.4-2014
Report Date:	08/07/2025
Test number:	PF22076

Table of Contents

1.1	Document revision schedule	3
1.2	Signatories	3
2.	Report Summary	4
3.	General Information	5
3.1	Testing Scope	5
3.2	Contact Details	5
3.3	Specimen Preparation, Conditioning and Timeline	6
3.4	Use of the Report	6
4.	Specimen Description	7
4.1	Supporting Construction	7
4.2	Specimen A	8
4.3	Specimen B	8
4.4	Specimen C	9
4.5	Specimen D	10
4.6	Specimen E	10
5.	Test Results	11
5.1	Observations during the test	11
5.2	Specimen A – D2 Cable Configuration	12
5.3	Specimen B – D1 Cable Configuration	13
5.4	Specimen C – 40mm Blank Seal	14
5.5	Specimen D – 32DN Copper Pipe	15
5.6	Specimen E – 20mm Vertical Linear Gap	16
6.	Photos	17

1.1 Document revision schedule

Revision #	Date	Description
1	08/07/2025	Issued

1.2 Signatories

Report	Name	Signature	Date
Prepared by:	Alexey Kokorin		08/07/2025
Authorised by:	Andrew Bain (Authorized signatory)		08/07/2025



All tests reported herein
have been performed in
accordance with the
laboratory's scope of
accreditation

2. Report Summary

A 64mm steel stud frame, lined with 2 x 13mm FR plasterboard on each side was constructed. Steel studs were installed to accommodate a vertical linear gap, cable trays, copper pipe and a blank seal. Two studs were installed back to back spaced 20mm apart prior to lining the wall. Plasterboard was cut out along the studs to reveal a 20mm linear gap. Additional penetrations for D1 and D2 cable tray configurations, copper pipe and blank seal were cut. All services were protected using FIRESTOP Ultra sealant with or without ceramic fibre blanket.

Specimen	Joint	Actual Integrity (min)	Actual Insulation (min)	FRL
A	D2 cable configuration	123 NF	123 NF	-/120/120
B	D1 cable configuration	123 NF	123 NF	-/120/120
C	40mm blank seal	123 NF	123 NF	-/120/120
D	DN32 Copper pipe	123 NF	123 NF	-/120/120
E	20mm Vertical Linear Gap seal	123 NF	123 NF	-/120/120

NF indicates no failures observed during test

3. General Information

3.1 Testing Scope

Applicable Standards:

AS 1530-2014 Part 4: Section 10 Service penetrations and control joints.

AS 4072.1-2005 Part 1: Service penetrations and control joints

Departures from Testing Method:

No departures from the testing method

Test conditions:

Conditions complied with the Standard

3.2 Contact Details

Accredited Testing Laboratory

FTSL - Passive Fire Inspection and Test Services Ltd

Accreditation Number - 1335

1/113 Pavilion Drive, Mangere, Auckland, 2022

New Zealand

Contact e-mail: tests@firelab.co.nz

Issued to:

Firestop Centre Ltd.

657 Great South Rd, Penrose, Auckland, 1061

New Zealand

Contact e-mail: info@firestopcentre.co.nz

3.3 Specimen Preparation, Conditioning and Timeline

Specimens conditioning and delivery to Laboratory:

Separating element was built by the Laboratory in line with Client instructions. Installation of fire stopping system was performed by Laboratory in line with Client instructions. The Laboratory was not involved in sampling of the materials. The Laboratory checked materials during construction of the specimen.

Testing date:

27/02/2023

Installation completion date:

22/01/2023

Termination of The Test:

The test was discontinued at 123 minutes.

3.4 Use of the Report

A regulatory information report was issued in addition to the full test report PF22076. This provides the minimum information required for regulatory compliance

This report shall not be reproduced, except in full.

The specimen was a symmetrical construction. The results of the test apply if exposed to fire from either side. This report details the methods of construction, test conditions and the results obtained when the specific element of construction described herein was tested following the procedure outlined in AS 1530.4. Any significant variation with respect to size, constructional details, loads, stresses, edge or end conditions, other than that allowed under the field of direct application in the relevant test method, is not covered by this report.

Because of the nature of fire resistance testing and the consequent difficulty in quantifying the uncertainty of measurement of fire resistance, it is not possible to provide a stated degree of accuracy of the result.

The test results relate to the specimens of the product in the form in which they were tested. Differences in the composition or thickness of the product may significantly affect the performance during the test and may therefore invalidate the test results. Care should be taken to ensure that any product, which is supplied or used, is fully represented by the specimens, which were tested.

The specimens were supplied by the sponsor and the Laboratory was not involved in any of selection or sampling procedures. The results of these fire tests may be used to directly assess fire hazard, but it should be recognized that a single test method will not provide a full assessment of fire hazard under all fire conditions.

4. Specimen Description

4.1 Supporting Construction

Separating Element		
1.1	Item / Product Name	Steel Stud and Plasterboard Separating element
	Measurements	Width / Height (W/H): 1200mm x 1200mm
		Wall Thickness: 116mm
		Cavity: 64mm
1.2	Item / Product Name	Steel Stud
	Measurements	Width / Height (W/H): 64mm x 35.5mm
		Thickness (T): 0.50BMT
	Additional Info	Used to construct separating element
1.3	Item / Product Name	Steel Deflection Track
	Measurements	Width / Height (W/H): 64mm x 50mm
		Thickness (T): 0.75BMT
	Additional Info	Used to construct separating element
1.4	Item / Product Name	13mm FR Plasterboard
	Measurements	Width / Height (W/H): 1200mm x 3000mm
		Thickness (T): 13mm
	Additional Info	2 x layers installed to each side of steel frame
4.1	Item / Product Name	Self-Tapping Screws
	Measurements	32mm
	Installation	Used to fix plasterboard to steel stud
4.2	Item / Product Name	Self-Tapping Screws
	Measurements	41mm
	Installation	Used to fix plasterboard to steel stud
4.3	Item / Product Name	Metal Screw
	Measurements	8g x 25mm
	Installation	Used to fix framing components

4.2 Specimen A

3.1	Item / Product Name	Formulation F023SDW01 - FIRESTOP Ultra sealant
	Dimensions	600mL
	Installation	Installed in annular gap + 50x70mm cone
2.1	Item / Product Name	Communications Cable 50 Pair
	Measurements	Outer Diameter (OD): 16mm (nominal)
	Additional Info	60 x cables installed in cable tray
2.2	Item / Product Name	Steel Cable Tray
	Measurements	Width / Height (W/H): 170mm x 50mm
	Additional Info	Installed through aperture
5.1	Item / Product Name	Ceramic Fibre Blanket
	Measurements	Width / Height (W/H): 610mm x 7200mm
		Thickness (T): 25mm
		Density (ρ): 128Kg/m ³
	Additional Info	Wrapped around service 2 x times with an additional 150mm overlap, extending 300mm from separating element
4.4	Item / Product Name	Stainless-Steel Cable Ties
	Measurements	10mm x 1000mm
	Installation	Used to fix wrap around services 100mm from ends of wrap

4.3 Specimen B

3.1	Item / Product Name	Formulation F023SDW01 - FIRESTOP Ultra sealant
	Dimensions	600mL
	Installation	Installed in annular gap + 50x70mm cone
2.3	Item / Product Name	XLPE/PVC 1 x 630mm ² Copper Cable
	Measurements	Outer Diameter (OD): 42mm (nominal)
	Additional Info	1 x cable installed in cable tray
2.4	Item / Product Name	4 x 185mm ² Aluminium Cable

	Measurements	Outer Diameter (OD): 49mm (nominal)
	Additional Info	1 x cable installed in cable tray
2.5	Item / Product Name	3 x 6mm ² + Earth Copper Cable (4G6)
	Measurements	Outer Diameter (OD): 16mm (nominal)
	Additional Info	3 x cables installed in cable tray
2.6	Item / Product Name	3 x 16mm ² + Earth Copper Cable (4G16)
	Measurements	Outer Diameter (OD): 16mm (nominal)
	Additional Info	8 x cables installed in cable tray
2.7	Item / Product Name	Steel Cable Tray
	Measurements	Width / Height (W/H): 325mm x 50mm
	Additional Info	Installed through aperture
5.1	Item / Product Name	Ceramic Fibre Blanket
	Measurements	Width / Height (W/H): 610mm x 7200mm
		Thickness (T): 25mm
		Density (ρ): 128Kg/m ³
	Additional Info	Wrapped around service 2 x times with additional 150mm overlap, extending 300mm from separating element
4.4	Item / Product Name	Stainless-Steel Cable Ties
	Measurements	10mm x 1000mm
	Installation	Used to fix wrap around services 100mm from ends of wrap

4.4 Specimen C

3.1	Item / Product Name	Formulation F023SDW01 - FIRESTOP Ultra sealant
	Dimensions	600mL
	Installation	Installed in aperture to form 40mm blank seal

4.5 Specimen D

3.1	Item / Product Name	Formulation F023SDW01 - FIRESTOP Ultra sealant
	Dimensions	600mL
	Installation	Installed in annular gap + 50x70mm cone
2.8	Item / Product Name	DN32 Copper Pipe
	Measurements	Outer Diameter (OD): 32mm
		Inner Diameter (ID): 29.5mm
		Thickness (T): 1.25mm
	Additional Info	Installed through aperture
5.1	Item / Product Name	Ceramic Fibre Blanket
	Measurements	Width / Height (W/H): 610mm x 7200mm
		Thickness (T): 25mm
		Density (ρ): 128Kg/m ³
	Additional Info	Wrapped around service 2 x times with additional 150mm overlap, extending 300mm from separating element
4.4	Item / Product Name	Stainless-Steel Cable Ties
	Measurements	10mm x 1000mm
	Installation	Used to fix wrap around services 100mm from ends of wrap

4.6 Specimen E

3.1	Item / Product Name	Formulation F023SDW01 - FIRESTOP Ultra sealant
	Dimensions	600mL
	Installation	Installed in linear gap to thickness of the plasterboard, resulting in a 26mm (nominal) seal

5. Test Results

5.1 Observations during the test

Time Minutes	Test Face	SP	Observations
1	U	A	Smoke from cables and wrap
2	U	B	Smoke from cables and wrap
5	U	A, B	Increase in amount of smoke from cables and wrap
15	E	C, E	Visible charring of sealant
20	U	B	Visible deforming of cable sheathing near TC20
20	E	A, B	Cable sheathing has combusted, and melting away from cable
20	E	A, B	Visible cracks between separating element and sealant
30	E/U	ALL	No notable changes
45	E/U	ALL	No notable changes
60	E/U	ALL	No notable changes
65	U	B	Reduced amount of smoke from specimen
65	U	A, B	Discolouring of wrap above cables
75	E/U	ALL	No notable changes
90	E/U	ALL	No notable changes
105	U	C, E	Visible expansion of sealant
120	E/U	ALL	No notable changes
123			TEST DISCONTINUED

**NOTE: E – Exposed Face (inside furnace),
U – Unexposed Face (outside furnace)
SE – Separating element**

5.2 Specimen A – D2 Cable Configuration

Service	D2 cable configuration
Service Details	Cables (2.1), Cable Tray (2.2) Sealant (3.1), Ceramic Fibre Blanket (5.1), Cable Ties (4.4)
Aperture Size	179mm x 128mm
Annular Spacing	Min: 5mm, Max: 20mm
Local Fire-stopping Protection	
Application	Symmetrical
Protection Used	Aperture was cut into the separating element. The 60 x D2 Cables (2.1) were bundled using cable ties and placed on the cable tray (2.2). The Cable tray was placed through the aperture, extending 500mm from the exposed face. Sealant (3.1) was installed between the cable tray and the separating element, flush with the plasterboard, resulting in a 26mm (nominal) seal. An additional 50mm x 70mm cone of sealant was applied between the cable tray and separating element. The cone extended 50mm from the cable bundle onto the separating element, and 70mm along the cables. Once the sealant had cured, the cable tray was wrapped with ceramic blanket (5.1). Two revolutions were applied around the cable tray, with 150mm (nominal) overlap. The wrap extended 300mm from the separating element, and was secured using two cable ties, spaced 100mm from each end of the wrap.

Structural adequacy	Not applicable
Integrity	No failure at 123 min
Insulation	No failure at 123 min

5.3 Specimen B – D1 Cable Configuration

Service	D1 cable configuration with the replacement of cable b)
Service Details	Cables (2.3, 2.4, 2.5, 2.6), Cable Tray (2.7) Sealant (3.1), Ceramic Fibre Blanket (5.1), Cable Ties (4.4)
Aperture Size	331mm x 64mm
Annular Spacing	Min: 1mm, Max: 63mm
Local Fire-stopping Protection	
Application	Symmetrical
Protection Used	Aperture was cut into the separating element. The 60 x D2 Cables (2.3, 2.4, 2.5, 2.6), were bundled into like groups using cable ties and evenly spaced on the cable tray (2.7). The Cable tray was placed through the aperture, extending 500mm from the exposed face. Sealant (3.1) was installed between the cable tray and the separating element, flush with the plasterboard, resulting in a 26mm (nominal) seal. An additional 50mm x 70mm cone of sealant was applied between the cable tray and separating element. The cone extended 50mm from the cable bundle onto the separating element, and 70mm along the cables. Once the sealant had cured, the cable tray was wrapped with ceramic blanket (5.1). Two revolutions were applied around the cable tray, with 150mm (nominal) overlap. The wrap extended 300mm from the separating element, and was secured using two cable ties, spaced 100mm from each end of the wrap.

Structural adequacy	Not applicable
Integrity	No failure at 123 min
Insulation	No failure at 123 min

5.4 Specimen C – 40mm Blank Seal

Service	40mm blank seal
Service Details	Sealant (3.1)
Local Fire-stopping Protection	
Application	Symmetrical
Protection Used	Aperture was cut into the separating element. Sealant (3.1) was installed in the aperture, flush with the plasterboard, resulting in a 26mm (nominal) seal.

Structural adequacy	Not applicable
Integrity	No failure at 123 min
Insulation	No failure at 123 min



5.5 Specimen D – 32DN Copper Pipe

Service	DN32 Copper pipe
Service Details	Pipe (2.8), Sealant (3.1), Ceramic Fibre Blanket (5.1), Cable Ties (4.4)
Aperture Size	32mm
Annular Spacing	Min: 0mm, Max: 1mm
Local Fire-stopping Protection	
Application	Symmetrical
Protection Used	Aperture was cut into the separating element. The pipe (2.8) was placed through the aperture, extending 500mm from the exposed face. A 50mm x 70mm cone of sealant was applied between the pipe and separating element. The cone extended 50mm from the pipe onto the separating element, and 70mm along the pipe. Once the sealant had cured, the cable tray was wrapped with ceramic blanket (5.1). Two revolutions were applied around the pipe, with 150mm (nominal) overlap. The wrap extended 300mm from the separating element, and was secured using two cable ties, spaced 100mm from each end of the wrap.

Structural adequacy	Not applicable
Integrity	No failure at 123 min
Insulation	No failure at 123 min


5.6 Specimen E – 20mm Vertical Linear Gap

Service	20mm wide Vertical Linear Gap seal
Joint Details	Sealant (3.1)
Local Fire-stopping Protection	
Application	Symmetrical
Protection Used	Aperture was cut into the separating element. Sealant (3.1) was installed in the aperture, flush with the plasterboard, resulting in a 26mm (nominal) seal.

Structural adequacy	Not applicable
Integrity	No failure at 123 min
Insulation	No failure at 123 min

6. Photos

Unexposed faced:



Exposed face:

